

What Happened?

- Overcharged system i.e. too much refrigerant
- Undercharged system
- Leaks in system
- Obstructions

Technician Solutions

- Charge system to appropriate level
- Recommend replacement if damage has occurred

Although this would be considered a closed system, equipment can have leaks or technicians may add too much charge to a system. Refrigerant charging is tested during an annual maintenance agreement and the issue can be corrected before a significant failure.

